# E-Rate Cabling, Rack, and Service Requirements

Please clarify the following items so bidders can prepare proposals that meet the project requirements.

## 1. Walkthrough and Installation Requirements

- Is a site walkthrough available so bidders can verify cable paths, ceiling access, rack locations, and elevated-work requirements?
    - Yes, A walkthrough can be scheduled.

- Can the cabling and rack installation be quoted separately, or must one provider quote the complete package?
    - This is for Installation and Racks, complete package
- Will you accept a bid covering only the Category 2 cabling and racks?
    - Yes
- Is plenum-rated cable required for the CAT6A cabling?
    - Yes
- Do the racks need to be lockable enclosures, or are standard open racks acceptable?
    - Lockable

## 2. E-Rate Prime and Subcontractor Requirements

- May a qualified E-Rate prime contractor include a field-installation subcontractor?
    - No
- If subcontractors are permitted, what SPIN, licensing, insurance, and registration requirements apply to the subcontractor?

## 3. Bid Submission Timeline

- Is there a final proposal receipt deadline (date and time) that is separate from the November 23 allowable contract date?
    - No

## 4. Category 1 — Internet Access and Data Transmission Service

- Could you please provide the addresses for both Category 1 entities?

  3800 Fettler Park Drive, Suite 103 Dumfries, VA 22025
  11835 Hazel Circle Drive Bristow, VA 20136