

Questions and answers from the walkthrough

Is this a rip and replace of cable? **Yes**

Are you wanting a cabler to go back with the same amount of drops? **It will be the same or less drops per wall.**

Is Panduit cable okay to use? **We are requesting General Cable but will accept functional equivalents.**

Do you want 1 ft patch cables? **The racks would have to be reconfigured to allow for one foot cables to work. You can include one foot patch cables if you would like but it is not a requirement.**

What cables are not getting replaced? **Any existing cat 6 cable using our standard or any cat 6a cable currently in place.**

In the kitchen area, you have underground conduit. Do you want to have an indoor/outdoor rated cable in case of moisture? **With how short the underground runs are, we are not requesting an indoor/outdoor cable to be used but we will allow it should it be bid that way.**

Is some of the cable in walls and in surface conduit? **Yes, we have both in some locations however the majority of cable is in the walls.**

Do you have different colored modular jacks for different data types? **We have the Panduit Keystone cat 6a jacks in black for access points but for this project you will only be using the blue Panduit Keystone cat6 jacks as we are not replacing any cat 6a cabling. The blue jacks are used for all other data types.**

Do you have a lift or will one be required? **We have a flat surface lift that can be used inside the building only.**