
SHEET NOTES

4	RECEPTACLE INSTALLED BELOW COUNTER. TRENCH AS REQUIRED FOR INSTALLATION OF NEW RECEPTACLE UNDER TABLE
5	RELOCATE ALL EXISTING TO REMAIN DATA CABLING FROM WALL MOUNTED RACK TO NEW FLOOR MOUNTED RACK IN NEW LOCATION. AS PART OF THE BASE BID, INCLUDE RELOCATION OF ALL EQUIPMENT, WIRING, AND NEW EQUIPMENT AS SHOWN INTO NEW IT ROOM.
6	PROVIDE FIRESTOPPING SLEEVE FOR 2HR RATED WALL FOR ALL CONDUIT AND CABLING PASSING THROUGH WALL.
7	18" LADDER RACK MOUNTED 7'-6" AFF - HOFFMAN #LSS18 SERIES OR EQUAL. (TYP.)
8	24" LADDER RACK MOUNTED 7'-6" AFF - HOFFMAN #LSS18 SERIES OR EQUAL. (TYP.)
9	TECHNOLOGY GROUND BUS BAR
10	CONFIRM ELECTRICAL REQUIREMENTS WITH OWNER FOR OWNER-PROVIDED EQUIPMENT.
11	CONFIRM EXACT LOCATION OF FLOOR BOX WITH ARCHITECT.
12	ALTERNATE #4: REINSTALLATION OF EXISTING CEILING SPEAKERS IN THIS ROOM.
13	CAMERA MOUNTED TO UNDERSIDE OF CANOPY. COORDINATE WITH OWNER



1 E201 **Electrical Power Main Level Floor Plan**
1/8" = 1'-0"

Key Plan



intersect

MILLIES
ENGINEERING GROUP
9711 Valparaiso Drive, Munster, IN 46321
221 N. LaSalle Street, Chicago, IL 60601
800 Monroe Ave NW, Grand Rapids, MI 49503
(219)924-8400
www.milliesengineeringgroup.com

Copyright © 2026 Millies Engineering Group

West Catholic High School
Innovation and Design Center
1801 Bristol Ave NW Grand Rapids MI 49504

STATE OF MICHIGAN
DAVID G JANNEY
ENGINEER
No. 6200064941
PROFESSIONAL ENGINEER

PB Addendum 3 10/30/2026
Bid/Permit Set 10/02/2026

© 2026, intersect studio, llc
Project Number: 25-016

Electrical Power Main Level Floor Plan

E201